



CERTIFICATE FOR GREEN AUDIT

Certificate Number: **PSQC1052**

This is to certify that, we have conducted a **GREEN AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110** during 23 June 2023.

The Audit investigates the following activities.

1. Coverage of matured trees (nearly 109 trees available in the college campus)
2. Implementation of many flowers, shrubs and indoor plants
3. Assessment of water distribution work
4. Future expansion of Thermal Energy for regular activities
5. Identification of expansion of green coverage for planting more trees

The detailed campus Greenery Coverage and initiatives are presented in the Audit Report

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL

**RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL.**



CERTIFICATE FOR ENVIRONMENTAL AUDIT

Certificate Number: PSQC1054

This is to certify that, we have conducted an **ENVIRONMENTAL AUDIT** in RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110 during 23 July 2023. This Audit highlights the energy balance sheet indicating various energy carriers associated with the regular activities of the institution and their CO₂ mapping.

Environmental system: CO₂ Balance sheet (2022-2023)

S. No	Energy Consumption & CO ₂ Emission			CO ₂ Neutralization		
	Description	Annual Usage	CO ₂ Emission (Tons/Annum)	Description	Annual Usage	CO ₂ Emission (Tons/Annum)
1	Electrical Energy	112328 kWh	92.1	Matured Trees	109 Nos.	2.38
5	Total Emission		92.1	Total Neutralized		2.38
Balance CO ₂ to be Neutralized				89.72 Tons/Annum		
CO ₂ Accountability for RAAK Arts and Science College Campus				1310.7 Tons/Annum¹		
(Calculated based on the weighted average of total strength of students, teaching and technical staff = 1040)						

System Audited

Electricity consumption	Usage of Chemical, Salts, Acids & Cleaning Agents
Diesel consumption (Transport)	Solid and E-waste Handling & Management
RO and water distribution system	

The detailed environmental aspects & impacts are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL:



CERTIFICATE FOR ENERGY AUDIT

Certificate Number: **PSQC1053**

This is to certify that, we have conducted an **ENERGY AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110** during 23 June 2023. The Audit team has identified 06 Energy Conservation Proposals (ENCONs) and summary of the energy audit is given below.

Description/Year	2022-23		
Annual Electricity Consumption (kWh)	1,12,328 kWh		
Summary of Energy Conservation (ENCON) Proposals			
Description	Parameters		
	Present	After	Savings
Annual Energy Consumption	1,12,328 kWh	95,479 kWh	16,849 kWh
Annual Energy Cost	19.84 lakhs	18.06 lakhs	1.78 lakhs
Simple Payback Period	---	---	1.5 years

Equipment's/Systems Audited

Electrical System	Thermal System
Electrical System & Network	Diesel generators, pumps and motors
Lighting, Fan & Air Conditioning System	Inverter, UPS and Battery System

The detailed Energy Conservation Proposals are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL

**RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL**



CERTIFICATE FOR GREEN AUDIT

Certificate Number: PSQC996

This is to certify that, we have conducted a **GREEN AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110 during 14th July 2022** (for the academic year 2021-2022).

The Audit investigates the following activities.

1. Coverage of matured trees (nearly 100 trees available in the college campus)
2. Future expansion of the thermal energy system for regular activities
3. Evaluation of solid, liquid and e-waste management system
4. Identification of expansion of green coverage for planting more trees
5. Evaluation of water distribution network

The detailed campus Greenery Coverage and initiatives are presented in the Audit Report

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21 875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625




PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL.



CERTIFICATE FOR ENERGY AUDIT

Certificate Number: PSQC997

This is to certify that, we have conducted an **ENERGY AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110** during 14th July 2022 (for the academic year 2021-2022). The Audit team has identified 08 Energy Conservation Proposals (ENCONs) and summary of the energy audit is given below.

Description/Year	2021-22		
Annual Electricity Consumption (kWh)	1,23,561 kWh		
Summary of Energy Conservation (ENCON) Proposals			
Description	Parameters		
	Present	After	Savings
Annual Energy Consumption	1,23,561 kWh	1,05,027 kWh	18,534 kWh
Annual Energy Cost	8.64 lakhs	7.35 lakhs	1.29 lakhs
Simple Payback Period	---	---	1.5 years

Equipment's/Systems Audited

Electrical System	Thermal System
Electrical System & Network	Diesel, generators, pumps and motors
Lightings, Fans and Air conditioning system	Inverter, UPS and battery system

The detailed Energy Conservation Proposals are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor – ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy – Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625




PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL.



CERTIFICATE FOR ENVIRONMENTAL AUDIT

Certificate Number: PSQC998

This is to certify that, we have conducted an **ENVIRONMENTAL AUDIT** in RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110 during 14th July 2022 (for the academic year 2021-2022). This Audit highlights the energy balance sheet indicating various energy carriers associated with the regular activities of the institution and their CO₂ mapping.

Environmental system: CO₂ Balance sheet (2021-2022)

S. No	Energy Consumption & CO ₂ Emission			CO ₂ Neutralization		
	Description	Annual Usage	CO ₂ Emission (Tons/Annum)	Description	Annual Usage	CO ₂ Emission (Tons/Annum)
1	Electrical Energy	123561 kWh	101.32	Matured Trees	100 Nos	2.18
2	Total Emission		101.32	Total Neutralized		2.18
Balance CO ₂ to be Neutralized				99.14 Tons/Annum		
CO ₂ Accountability for RASC Campus				1533.42 Tons/Annum¹		
(Calculated based on the weighted average of total strength of students, teaching and technical staff = 1217)						

System Audited

Electricity Consumption	Usage of Chemicals, Salts, Acids & Cleaning Agents
Diesel Consumption (Transport)	Solid E-waste Handling & Management
RO and Water distribution system	

The detailed environmental aspects & impacts are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL.



CERTIFICATE FOR **GREEN AUDIT**

Certificate Number: PSQC993

This is to certify that, we have conducted a **GREEN AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110** during 15th July 2021 (for the academic year 2020-2021).

The Audit investigates the following activities.

1. Coverage of matured trees (nearly 94 trees available in the college campus)
2. Implemented many shrubs and indoor plants
3. Assessment of RO water distribution network
4. Evaluation of solid and E-waste management system
5. Future expansion of thermal energy system

The detailed campus Greenery Coverage and initiatives are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL



CERTIFICATE FOR ENERGY AUDIT

Certificate Number: PSQC994

This is to certify that, we have conducted an **ENERGY AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110** during 15th July 2021 (for the academic year 2020-2021). The Audit team has identified 10 Energy Conservation Proposals (ENCONs) and summary of the energy audit is given below.

Description/Year	2020-21		
Annual Electricity Consumption (kWh)	1,35,917 kWh		
Summary of Energy Conservation (ENCON) Proposals			
Description	Parameters		
	Present	After	Savings
Annual Energy Consumption	1,35,917 kWh	1,15,530 kWh	20,387 kWh
Annual Energy Cost	9.51 lakhs	8.08 lakhs	1.43 lakhs
Simple Payback Period	---	---	1.5 years

Equipment's/Systems Audited

Electrical System	Thermal System
Electrical System & Network	Diesel, generators, pumps and motors
Lightings, Fans and Air conditioning system	Inverter, UPS and battery system

The detailed Energy Conservation Proposals are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL.



CERTIFICATE FOR ENVIRONMENTAL AUDIT

Certificate Number: PSQC995

This is to certify that, we have conducted an **ENVIRONMENTAL AUDIT** in RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110 during 15th July 2021 (for the academic year 2020-2021). This Audit highlights the energy balance sheet indicating various energy carriers associated with the regular activities of the institution and their CO₂ mapping.

Environmental system: CO₂ Balance sheet (2020-2021)

S. No	Energy Consumption & CO ₂ Emission			CO ₂ Neutralization		
	Description	Annual Usage	CO ₂ Emission (Tons/Annum)	Description	Annual Usage	CO ₂ Emission (Tons/Annum)
1	Electrical Energy	135917 kWh	111.45	Matured Trees	94 Nos	2.05
2	Total Emission		111.45	Total Neutralized		2.05
Balance CO ₂ to be Neutralized				109.4 Tons/Annum		
CO ₂ Accountability for RASC Campus				1823.22 Tons/Annum ¹		

(Calculated based on the weighted average of total strength of students, teaching and technical staff = 1447)

System Audited

Electricity Consumption	Usage of Chemicals, Salts, Acids & Cleaning Agents
Diesel Consumption (Transport)	Solid E-waste Handling & Management
RO and Water distribution system	

The detailed environmental aspects & impacts are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL.



CERTIFICATE FOR **GREEN AUDIT**

Certificate Number: PSQC983

This is to certify that, we have conducted a **GREEN AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110** during 17th July 2020 (for the academic year 2019-2020).

The Audit investigates the following activities.

1. Coverage of matured trees (nearly 89 trees available in the college campus)
2. Implemented many shrubs
3. Assessment of water distribution network
4. Identification of expansion of green coverage for planting more trees

The detailed campus Greenery Coverage and initiatives are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.


(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625




PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLUPURAM, POST-605 110
PERAMBAL.



CERTIFICATE FOR ENERGY AUDIT

Certificate Number: PSQC984

This is to certify that, we have conducted an **ENERGY AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT - 605 110** during 17th July 2020 (for the academic year 2019-2020). The Audit team has identified 12 Energy Conservation Proposals (ENCONs) and summary of the energy audit is given below.

Description/Year	2019-20		
Annual Electricity Consumption (kWh)	1,49,508 kWh		
Summary of Energy Conservation (ENCON) Proposals			
Description	Parameters		
	Present	After	Savings
Annual Energy Consumption	1,49,508 kWh	1,27,082 kWh	22,426 kWh
Annual Energy Cost	10.46 lakhs	8.89 lakhs	1.56 lakhs
Simple Payback Period	---	---	1.5 years

Equipment's/Systems Audited

Electrical System	Thermal System
Electrical System & Network	Diesel, generators, pumps and motors
Lightings, Fans and Air conditioning system	Inverter, UPS and battery system

The detailed Energy Conservation Proposals are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
WILLIANUR POST-605 110
PERAMBAL.



CERTIFICATE FOR ENVIRONMENTAL AUDIT

Certificate Number: PSQC985

This is to certify that, we have conducted an **ENVIRONMENTAL AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110** during 17th July 2020 (for the academic year 2019-2020). This Audit highlights the energy balance sheet indicating various energy carriers associated with the regular activities of the institution and their CO₂ mapping.

Environmental system: CO₂ Balance sheet (2019-2020)

S. No	Energy Consumption & CO ₂ Emission			CO ₂ Neutralization		
	Description	Annual Usage	CO ₂ Emission (Tons/Annum)	Description	Annual Usage	CO ₂ Emission (Tons/Annum)
1	Electrical Energy	149508 kWh	122.59	Matured Trees	89 Nos	1.94
2	Total Emission		122.59	Total Neutralized		1.94
Balance CO ₂ to be Neutralized				120.65 Tons/Annum		
CO ₂ Accountability for RASC Campus				2196.18 Tons/Annum¹		
(Calculated based on the weighted average of total strength of students, teaching and technical staff = 1743)						

System Audited

Electricity Consumption	Usage of Chemicals, Salts, Acids & Cleaning Agents
Diesel Consumption (Transport)	Solid E-waste Handling & Management
RO and Water distribution system	

The detailed environmental aspects & impacts are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625

Web Site: www.psqualitycertifications.com



PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL.



CERTIFICATE FOR GREEN AUDIT

Certificate Number: **PSQC971**

This is to certify that, we have conducted a **GREEN AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT - 605 110** during 18th July 2019 (for the academic year 2018-2019).

The Audit investigates the following activities.

1. Coverage of matured trees (nearly 83 trees available in the college campus)
2. Implemented many shrubs
3. Assessment of water distribution network
4. Evaluation of solid and E-waste management system
5. Identification of expansion of green coverage for planting more trees

The detailed campus Greenery Coverage and initiatives are presented in the Audit Report.

Authorized Auditor


G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL.





CERTIFICATE FOR **ENERGY AUDIT**

Certificate Number: PSQC972

This is to certify that, we have conducted an **ENERGY AUDIT** in **RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT - 605 110** during 18th July 2019 (for the academic year 2018-2019). The Audit team has identified 14 Energy Conservation Proposals (ENCONs) and summary of the energy audit is given below.

Description/Year	2018-19		
Annual Electricity Consumption (kWh)	1,64,459 kWh		
Summary of Energy Conservation (ENCON) Proposals			
Description	Parameters		
	Present	After	Savings
Annual Energy Consumption	1,64,459 kWh	1,39,791 kWh	24,668 kWh
Annual Energy Cost	11.51 lakhs	9.78 lakhs	1.72 lakhs
Simple Payback Period	---	---	1.5 years

Equipment's/Systems Audited

Electrical System	Thermal System
Electrical System & Network	Diesel, generators, pumps and motors
Lightings, Fans and Air conditioning system	Inverter, UPS and battery system

The detailed Energy Conservation Proposals are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL.



CERTIFICATE FOR ENVIRONMENTAL AUDIT

Certificate Number: PSQC973

This is to certify that, we have conducted an **ENVIRONMENTAL AUDIT** in RAAK ARTS AND SCIENCE COLLEGE, NO.1, BASHEER CAMPUS, PERAMBAL ROAD, PERAMBAL, VANUR (T.K.), VILLUPURAM DISTRICT – 605 110 during 18th July 2019 (for the academic year 2018-2019). This Audit highlights the energy balance sheet indicating various energy carriers associated with the regular activities of the institution and their CO₂ mapping.

Environmental system: CO₂ Balance sheet (2018-2019)

S. No	Energy Consumption & CO ₂ Emission			CO ₂ Neutralization		
	Description	Annual Usage	CO ₂ Emission (Tons/Annum)	Description	Annual Usage	CO ₂ Emission (Tons/Annum)
1	Electrical Energy	164459 kWh	134.86	Matured Trees	83 Nos	1.81
2	Total Emission		134.86	Total Neutralized		1.81
Balance CO ₂ to be Neutralized				133.05 Tons/Annum		
CO ₂ Accountability for RASC Campus				1852.2 Tons/Annum¹		
(Calculated based on the weighted average of total strength of students, teaching and technical staff = 1470)						

System Audited

Electricity Consumption	Usage of Chemicals, Salts, Acids & Cleaning Agents
Diesel Consumption (Transport + DG)	Solid E-waste Handling & Management
RO Plant and Water distribution system	

The detailed environmental aspects & impacts are presented in the Audit Report.

Authorized Auditor

G. ARIVARASAN

BEE Certified Energy Auditor (EA-21875)

Lead Auditor - ISO 14001, EMS

P S QUALITY CERTIFICATION PVT. LTD.

(Consultancy - Accreditation & Certification) Auditing & Training

E-mail: info@psqualitycertifications.com

Web Site: www.psqualitycertifications.com

CIN: U74999TN2020PTC138625



PRINCIPAL
RAAK ARTS & SCIENCE COLLEGE
VILLIANUR POST-605 110
PERAMBAL.